

CERTIFICATE OF COMPLIANCE

Certificate Number 20180430-E192487
Report Reference E192487-19990727
Issue Date 2018-APRIL-30

Issued to: Circuit Breaker Industries (Pty) Ltd
TRIPSWITCH DRIVE
ELANDSFONTEIN 1600 SOUTH AFRICA

**This is to certify that
representative samples of**

CIRCUIT BREAKERS, MOLDED CASE AND CIRCUIT-
BREAKER ENCLOSURES

USL, CNL - Molded case circuit breaker, Type QL-1 (13),
rated 0.1 through 25 A, 120 V ac, 0.1 through 20A, 240V
ac, one pole; QL 2 (13), rated 0.1 through 25 A, 120/240 V
ac, 2 pole and type QL-3 (13) rated 0.1 through 25 A 240V
ac.

(See Addendum Page for Additional Information)

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL489 - Standard For Safety For Molded-Case Circuit
Breakers, Molded-Case Switches and Circuit-Breaker
Enclosures


CSA C22.2 No. 5-13 - Standard For Safety For Molded-
Case Circuit Breakers, Molded-Case Switches and Circuit-
Breaker Enclosures

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180430-E192487
Report Reference E192487-19990727
Issue Date 2018-APRIL-30

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Addendum –

Ratings:

<u>Ampere Rating</u>	<u>Voltage Rating</u>	<u>Standard Interrupting Rating</u>	<u>Hi-Interrupting Rating</u>
0.1-25 A	120 V ac	5,000 A, 120 V ac	10,000 A, 120 V ac
0.1-25 A	120/240 V ac	5,000 A, 120/240 V ac	10,000 A, 120/240 V ac
0.1-20 A	240 V ac	5,000 A, 240 V ac	N/A
0.1-25A	240 V ac	5,000 A, 240 V ac	10,000 A, 240V ac



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

