

CERTIFICATE OF COMPLIANCE

Certificate Number 20180427-E204404
Report Reference E204404-20010112
Issue Date 2018-APRIL-27

Issued to: Circuit Breaker Industries (Pty) Ltd
TRIPSWITCH DRIVE
ELANDSFONTEIN 1600 SOUTH AFRICA

**This is to certify that
representative samples of**

**CIRCUIT BREAKERS FOR USE IN COMMUNICATIONS
EQUIPMENT**

Circuit breakers for use in communications equipment,
Type C Frame, rated 0.1 through 30 A, 30 V dc, 1 pole.
(See Addendum for Additional Model Information.)

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 489A - Circuit Breakers for Use in Communications
Equipment

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180427-E204404
Report Reference E204404-20010112
Issue Date 2018-APRIL-27

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Addendum -

Ratings:

<u>Ampere Rating</u>	<u>Voltage</u>	<u>Short-Circuit Rating</u>
0.1 - 30 A 1P	30 V dc	5000 A, 30 V dc



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

